



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

March 26, 2021

Mr. Michael Falcone
Greenburgh Central School District
475 West Hartsdale Avenue
Hartsdale, NY 10530

Re: **Richard Bailey ES - Pipe Insulation Abatement: March 2021**

Dear Mr. Falcone,

Please be advised that asbestos abatement work was completed at Richard J. Bailey Elementary School on March 26, 2021. Enviroscience Consultants, Inc. provided on site project monitoring for the duration of the abatement, performed on March 24th, 2021 by Environmental Maintenance Contractors, Inc. (EMC), in accordance with the New York State Department of Labor Industrial Code Rule 56 and applicable variances. Breakdown and demobilization from the site was completed on March 26th, 2021.

Asbestos containing materials removed are as follow;

- Approximately 75 linear feet of asbestos containing pipe insulation & elbows from room 004 & the Assistant Principal's Office.

Project monitoring was conducted by Enviroscience Consultant's project monitors Drew Cheskin & Glen Bornhoft. Final clearance air sampling inside and outside the work area(s) was performed on March 25th & 26th, 2021 in accordance with approved procedures. Final clearance air sampling indicates PCM levels below 0.01 f/cc, meeting re-occupancy criteria. A visual inspection of the abated areas was conducted and no visible debris was observed upon final completion of the removal. All pertinent project data will be compiled into a final project monitoring report and forwarded to your office.

Based upon the results of the final visual inspection, all areas may be released for re-occupancy. If you have any questions regarding this matter, feel free to contact me at (917) 696-6972.

Sincerely,

A handwritten signature in dark ink, appearing to read "Drew Cheskin", with a stylized flourish at the end.

Drew Cheskin


ELAP # 11681; NVLAP Lab Code 200531-0

PCM AIR SAMPLE RESULTS

CLIENT:	Greenburgh Central School District 475 West Hartsdale Avenue, Hartsdale, NY 10530	SAMPLE DATE:	3/24/2021
PROJECT NAME:	Richard Bailey ES - Pipe Insulation Abatement: March 2021	DATE RECEIVED:	3/25/2021
JOB #:	20675	AREA:	Music Room 004
PAGE #:	1 of 2	SAMPLE TYPE:	Final Clearance
		SAMPLER:	Glen Bornhoft
		CUSTODY #:	29494

Sample	Sample Location	Start	End	Run Time	Start F/R	End F/R	Volume	Filter Concentration fibers/mm ²	Air Concentration Fibers/cc
F1 IWA	Music Room 004 - Tent #2 (N)	15:01	16:21	80	15	15	1200	< 7.00	< 0.0022
F2 IWA	Music Room 004 - Tent #2 (W)	15:02	16:22	80	15	15	1200	< 7.00	< 0.0022
F3 IWA	Music Room 004 - Tent #2 (Ctr)	15:03	16:23	80	15	15	1200	< 7.00	< 0.0022
F4 IWA	Music Room 004 - Tent #2 (S)	15:04	16:24	80	15	15	1200	< 7.00	< 0.0022
F5 IWA	Music Room 004 - Tent #2 (E)	15:05	16:25	80	15	15	1200	< 7.00	< 0.0022
F6 IWA	Music Room 004 - Tent #1 (N)	15:11	16:31	80	15	15	1200	< 7.00	< 0.0022
F7 IWA	Music Room 004 - Tent #1 (W)	15:12	16:32	80	15	15	1200	< 7.00	< 0.0022
F8 IWA	Music Room 004 - Tent #1 (Ctr)	15:13	16:33	80	15	15	1200	< 7.00	< 0.0022
F9 IWA	Music Room 004 - Tent #1 (S)	15:14	16:34	80	15	15	1200	< 7.00	< 0.0022
F10 IWA	Music Room 004 - Tent #1 (E)	15:15	16:35	80	15	15	1200	< 7.00	< 0.0022
F11 OWA	Music Room 004 btwn Tents 1 & 2 - (N)	16:26	17:46	80	15	15	1200	< 7.00	< 0.0022
F12 OWA	Music Room 004 btwn Tents 1 & 2 - (W)	16:27	17:47	80	15	15	1200	< 7.00	< 0.0022
F13 OWA	Music Room 004 btwn Tents 1 & 2 - (Ctr)	16:28	17:48	80	15	15	1200	< 7.00	< 0.0022
F14 OWA	Music Room 004 btwn Tents 1 & 2 - (S)	16:29	17:49	80	15	15	1200	< 7.00	< 0.0022
F15 OWA	Music Room 004 btwn Tents 1 & 2 - (E)	16:30	17:50	80	15	15	1200	< 7.00	< 0.0022

Analyzed by:



Date Analyzed:

3/25/2021

Method: NIOSH 7400 – Phase Contrast Microscopy NYS ELAP No.: 11681 IHPAT ID# 206698, F/R=Flow Rate [liters per minute], Volume=Liters, F=Fibers, cc=cubic centimeters, mm=millimeters
 At the time of this analysis the analyst relative standard deviation is 0.45 for less than 20 fibers per 100 fields; it is 0.15 for 20 to 50 fibers per 100 fields and 0.39 for 50 to 100 fields. Envirosience Consultants, Inc. can only assure the fiber count per fields when samples are collected by outside agents. Airborne concentration (fiber/cc) cannot be assured when collected by outside agents.


ELAP # 11681; NVLAP Lab Code 200531-0

PCM AIR SAMPLE RESULTS

CLIENT:	Greenburgh Central School District 475 West Hartsdale Avenue, Hartsdale, NY 10530	SAMPLE DATE:	3/24/2021
PROJECT NAME:	Richard Bailey ES - Pipe Insulation Abatement: March 2021	DATE RECEIVED:	3/25/2021
JOB #:	20675	AREA:	Music Room 004
PAGE #:	2 of 2	SAMPLE TYPE:	Final Clearance
		SAMPLER:	Glen Bornhoft
		CUSTODY #:	29494

Sample	Sample Location	Start	End	Run Time	Start F/R	End F/R	Volume	Filter Concentration fibers/mm ²	Air Concentration Fibers/cc
F16	Field Blank						0	< 7.00	
F17	Sealed Blank						0	< 7.00	

Analyzed by:



Date Analyzed:

3/25/2021

Method: NIOSH 7400 – Phase Contrast Microscopy NYS ELAP No.: 11681 IHPAT ID# 206698, F/R=Flow Rate [liters per minute], Volume=Liters, F=Fibers, cc=cubic centimeters, mm=millimeters
 At the time of this analysis the analyst relative standard deviation is 0.45 for less than 20 fibers per 100 fields; it is 0.15 for 20 to 50 fibers per 100 fields and 0.39 for 50 to 100 fields. Enviroscience Consultants, Inc. can only assure the fiber count per fields when samples are collected by outside agents. Airborne concentration (fiber/cc) cannot be assured when collected by outside agents.


ELAP # 11681; NVLAP Lab Code 200531-0

PCM AIR SAMPLE RESULTS

CLIENT:	Greenburgh Central School District 475 West Hartsdale Avenue, Hartsdale, NY 10530	SAMPLE DATE:	3/25/2021
PROJECT NAME:	Richard Bailey ES - Pipe Insulation Abatement: March 2021	DATE RECEIVED:	3/25/2021
JOB #:	20675	AREA:	Assistant Principal's Office
PAGE #:	1 of 1	SAMPLE TYPE:	Final Clearance
		SAMPLER:	Drew Cheskin
		CUSTODY #:	29495

Sample	Sample Location	Start	End	Run Time	Start F/R	End F/R	Volume	Filter Concentration fibers/mm ²	Air Concentration Fibers/cc
F18 IWA	Assistant Principal's Tent	6:50	8:10	80	15	15	1200	< 7.00	< 0.0022
F19 IWA	Assistant Principal's Tent	6:50	8:10	80	15	15	1200	< 7.00	< 0.0022
F20 IWA	Assistant Principal's Tent	6:50	8:10	80	15	15	1200	< 7.00	< 0.0022
F21 IWA	Assistant Principal's Tent	6:51	8:11	80	15	15	1200	< 7.00	< 0.0022
F22 IWA	Assistant Principal's Tent	6:51	8:11	80	15	15	1200	< 7.00	< 0.0022
F23 OWA	Assistant Principal's Office	6:53	8:13	80	15	15	1200	< 7.00	< 0.0022
F24 OWA	Assistant Principal's Office	6:53	8:13	80	15	15	1200	< 7.00	< 0.0022
F25 OWA	Assistant Principal's Office	6:54	8:14	80	15	15	1200	< 7.00	< 0.0022
F26 OWA	Assistant Principal's Office	6:54	8:14	80	15	15	1200	< 7.00	< 0.0022
F27 OWA	Assistant Principal's Office	6:55	8:15	80	15	15	1200	7.64	0.0025
F28	Field Blank						0	< 7.00	
F29	Sealed Blank						0	< 7.00	

Analyzed by:



Date Analyzed:

3/25/2021

Method: NIOSH 7400 – Phase Contrast Microscopy NYS ELAP No.: 11681 IHPAT ID# 206698, F/R=Flow Rate [liters per minute], Volume=Liters, F=Fibers, cc=cubic centimeters, mm=millimeters
 At the time of this analysis the analyst relative standard deviation is 0.45 for less than 20 fibers per 100 fields; it is 0.15 for 20 to 50 fibers per 100 fields and 0.39 for 50 to 100 fields. Envirosience Consultants, Inc. can only assure the fiber count per fields when samples are collected by outside agents. Airborne concentration (fiber/cc) cannot be assured when collected by outside agents.