



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

December 17, 2021

Mr. Michael Falcone
Greenburgh Central School District
475 West Hartsdale Avenue
Hartsdale, NY 10530

Re: **Districtwide Legionella Water Testing**

Dear Mr. Falcone,

At the request of Greenburgh Central School District, EnviroScience Consultants, LLC. performed limited potable water sampling of the district's various school buildings. The intent of the sampling was to test for the presence of Legionella within each building's water systems. Sampling was performed at up to five different locations within each building to screen for Legionella. Locations sampled include;

- Hot water storage tank(s)
- Kitchen hot water faucet
- Ice machine
- Last point drinking water fountain/bottle filling station
- Last point on hot water system

Sampling was performed on Wednesday, November 17th, by Drew Cheskin & Glen Bornhoft. A 250 ml, sterile container was used to collect the sample from each applicable outlet and then placed on ice for delivery to a New York State Department of Health ELAP certified laboratory for analysis. Sampling was performed at the following buildings.

- Early Childhood Program (Three samples - no ice machine, no drinking fountain/bottle filler)
- Welcome Center (Two samples - no ice machine, no drinking fountain/bottle filler, no kitchen)
- Woodlands Middle/High School (Five samples)
- Lee F. Jackson Elementary School (Four samples - no ice machine)
- Richard J. Bailey Elementary School (Four samples - no ice machine)
- Highview Elementary School (Four samples - no ice machine)

Results from the sample analysis revealed two samples which contained detectable levels of Legionella;

- Richard J. Bailey Elementary School - Boiler Room - Hot Water Tank
- Richard J. Bailey Elementary School - 3rd Floor - Bottle Filler @ Boys Room

After corrective actions were taken by the district, Chris Ortiz performed follow-up testing of the following locations on Monday, December 6th;

- Richard J. Bailey Elementary School - Boiler Room - Hot Water Tank
- Richard J. Bailey Elementary School - 3rd Floor - Bottle Filler @ Boys Room
- Richard J. Bailey Elementary School - 3rd Floor - Boys Room Sink Left

Results from the follow-up testing did not identify any detectible level of Legionella in any of the three water sources retested at Richard J. Bailey Elementary School.

Please see attached chains of custody and sample results for each building sampled for this project.

EPA has established a Maximum Contaminant Level Goal (MCLG) of zero organisms for drinking water. An MCLG is a non-enforceable guideline based solely on an evaluation of possible health risks, taking into consideration a margin for public safety.

The remediation response would be hyperchlorination, flush and retest in the areas impacted.

Should you have any questions about these results, please do not hesitate to contact Glenn Neuschwender at 631-831-1648.

Sincerely,



Drew Cheskin

Lab Sample ID: 211117P023	Collected: 11/17/2021	8:52
Client ID: 1	Received: 11/17/2021	14:45
Description: Boiler Room - Hot Water Tank		

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.06	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	16.1	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P024	Collected: 11/17/2021	8:59
Client ID: 2	Received: 11/17/2021	14:45
Description: Kitchen - Sink Hot Water		

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.08	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.3	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P025	Collected: 11/17/2021	8:57
Client ID: 3	Received: 11/17/2021	14:45
Description: Main Office - Bathroom Sink Hot Water		

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.09	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	11.7	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

2215240



C 1 9 6 6 9

D Cheskin

[Signature]

11/17/21

14:45

C. Adams

Cara Adams

11/17/21

14:45

NYEA Project No.	Temp. 23.7 °C	Analyst Initials	Analysis Date:
------------------	---------------	------------------	----------------

SE

Lab Sample ID: 211117P021	Collected: 11/17/2021 9:02
Client ID: 1	Received: 11/17/2021 14:45
Description: Boiler Room - Hot Water Tank	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.07	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	14.1	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P022	Collected: 11/17/2021 9:04
Client ID: 2	Received: 11/17/2021 14:45
Description: 2nd Floor - Bathroom Sink Hot Water	


Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.06	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	15.7	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

Chain of Custody - Chemistry

2215239



C 1 9 6 6 8

D Cheskin

De

11/17/21

14:45

C. Adams

Cara Adams

$$\underline{11 \mid 17 \mid 21}$$

14:45

Lab Use Only:

NYEA Project No.	Temp. 23.7 °C	Analyst Initials	Analysis Date:
------------------	---------------	------------------	----------------

Lab Sample ID: 211117P034	Collected: 11/17/2021 9:40
Client ID: 1	Received: 11/17/2021 14:45
Description: Kitchen - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.11	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	9.30	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P035	Collected: 11/17/2021 9:39
Client ID: 2	Received: 11/17/2021 14:45
Description: Kitchen - Ice Machine	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.07	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.9	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P036	Collected: 11/17/2021 9:42
Client ID: 3	Received: 11/17/2021 14:45
Description: Boiler Room - Hot Water Tank	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.08	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.3	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P037	Collected: 11/17/2021 9:35
Client ID: 4	Received: 11/17/2021 14:45
Description: Gym Hallway - Bottle Filter	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.09	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	11.6	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P038	Collected: 11/17/2021 9:34
Client ID: 5	Received: 11/17/2021 14:45
Description: Sports Lockers - Bathroom Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.08	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	11.9	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

Chain of Custody - Chemistry

2215243



C 1 9 6 7 2

1) Cheskin

De

Date: 11/17/21

Time: 14:45

C. Adams

Cara Adams

Date: 11/17/21

Time: 14:45

Lab Use Only:

NYEA Project No.	Temp. 23.7 °C	Analyst Initials	Analysis Date:
------------------	---------------	------------------	----------------

Lab Sample ID: 211117P030	Collected: 11/17/2021 10:09
Client ID: 1	Received: 11/17/2021 14:45
Description: Boiler Room - Hot Water Tank	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.07	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.5	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P031	Collected: 11/17/2021 10:13
Client ID: 2	Received: 11/17/2021 14:45
Description: Kitchen - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.07	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.8	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P032	Collected: 11/17/2021 10:12
Client ID: 3	Received: 11/17/2021 14:45
Description: Bottle Filler @ Reading Room	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.08	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	13.3	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	


Lab Sample ID: 211117P033	Collected: 11/17/2021 10:17
Client ID: 4	Received: 11/17/2021 14:45
Description: Classroom 1 - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.11	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	8.80	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

2215242



C 1 9 6 7 1

D Cheskin
C. Adams

DE
Cora Adams

11/17/21

14:45

C. Adams

Cora Adams

10/17/2

14:45

NYEA Project No.	Temp. 23.7 °C	Analyst Initials	Analysis Date:
------------------	---------------	------------------	----------------

SE

Lab Sample ID: 211117P039	Collected: 11/17/2021 10:39
Client ID: 1	Received: 11/17/2021 14:45
Description: Boiler Room - Hot Water Sink	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/01/21	0.07	3.77	CFUs/mL	
Vol. Examined		12/01/21	n/a	14.6	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	12/01/21	n/a	08:40	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P040	Collected: 11/17/2021 10:42
Client ID: 2	Received: 11/17/2021 14:45
Description: Kitchen - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/01/21	0.07	ND	CFUs/mL	
Vol. Examined		12/01/21	n/a	14.6	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	12/01/21	n/a	08:40	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P041	Collected: 11/17/2021 10:45
Client ID: 3	Received: 11/17/2021 14:45
Description: 3rd Floor - Bottle Filler @ Boys Room	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/01/21	0.07	1.16	CFUs/mL	
Vol. Examined		12/01/21	n/a	14.7	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	12/01/21	n/a	08:40	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Lab Sample ID: 211117P042	Collected: 11/17/2021 10:47
Client ID: 4	Received: 11/17/2021 14:45
Description: 3rd Floor - Boys Room Sink Hot Water	


Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/01/21	0.07	ND	CFUs/mL	
Vol. Examined		12/01/21	n/a	14.0	mL	
Incubation Time In	Time	11/18/21	n/a	13:00	hh:mm	
Incubation Time Out	Time	12/01/21	n/a	08:40	hh:mm	
Residual Cl ₂	Chlorine Strip	11/18/21	0.1	<0.1	ppm	
Received Temp.		11/18/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

Chain of Custody - Chemistry

2215244



C 1 9 6 7 3

D Cheskin

De

Time: 14:45

C. Adams

Cara Adam

Time: 14:45

Lab Use Only:

85

Lab Sample ID: 211117P026	Collected: 11/17/2021 11:09
Client ID: 1	Received: 11/17/2021 14:45
Description: Boiler Room - Hot Water Tank	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.10	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	9.90	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P027	Collected: 11/17/2021 11:14
Client ID: 2	Received: 11/17/2021 14:45
Description: Kitchen - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.09	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	11.0	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P028	Collected: 11/17/2021 11:16
Client ID: 3	Received: 11/17/2021 14:45
Description: Classroom 15 - Sink Hot Water	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.09	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	11.7	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Lab Sample ID: 211117P029	Collected: 11/17/2021 11:19
Client ID: 4	Received: 11/17/2021 14:45
Description: Bottle Filler @ Classroom 4	

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	11/29/21	0.06	ND	CFUs/mL	
Vol. Examined		11/29/21	n/a	15.7	mL	
Incubation Time In	Time	11/17/21	n/a	15:20	hh:mm	
Incubation Time Out	Time	11/29/21	n/a	11:00	hh:mm	
Residual Cl ₂	Chlorine Strip	11/17/21	0.1	<0.1	ppm	
Received Temp.		11/17/21	n/a	23.7	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units ND: Analyte Not Detected LOQ: Limit of Quantitation

2215241



C 1 9 6 7 0

D Cheskin

DE

Time: 14:45

C. Adams

by: Cora Adams

Time: 14:45

NYEA Project No.	Temp. 23.7 °C	Analyst Initials	Analysis Date:
------------------	---------------	------------------	----------------

Lab Sample ID: 211206M011	Collected: 12/6/2021 10:32
Client ID: 1	Received: 12/6/2021 12:06
Description: Boiler Room-Hot Water Tank	Disinfectant/Biocide:

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/16/21	0.37	ND	CFUs/mL	
Vol. Examined		12/16/21	n/a	2.72	mL	
Incubation Time In	Time	12/06/21	n/a	14:45	hh:mm	
Incubation Time Out	Time	12/16/21	n/a	14:20	hh:mm	
Residual Cl	Chlorine Strip	12/06/21	0.1	<0.1	ppm	
Received Temp.		12/06/21	n/a	21.6	°C	

Lab Sample ID: 211206M012	Collected: 12/6/2021 10:36
Client ID: 2	Received: 12/6/2021 12:06
Description: 3rd Floor- Bottle Filler @ Boys Room	Disinfectant/Biocide:

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/16/21	0.36	ND	CFUs/mL	
Vol. Examined		12/16/21	n/a	2.80	mL	
Incubation Time In	Time	12/06/21	n/a	14:45	hh:mm	
Incubation Time Out	Time	12/16/21	n/a	14:20	hh:mm	
Residual Cl	Chlorine Strip	12/06/21	0.1	<0.1	ppm	
Received Temp.		12/06/21	n/a	21.6	°C	

Lab Sample ID: 211206M013	Collected: 12/6/2021 10:50
Client ID: 3	Received: 12/6/2021 12:06
Description: 3rd Floor Boys BR SK Left	Disinfectant/Biocide:

Parameter	Method	Analysis Date	LOQ	Result	Units	Flag(s)
Colony Count	ISO 11731 (2017)	12/16/21	0.36	ND	CFUs/mL	
Vol. Examined		12/16/21	n/a	2.77	mL	
Incubation Time In	Time	12/06/21	n/a	14:45	hh:mm	
Incubation Time Out	Time	12/16/21	n/a	14:20	hh:mm	
Residual Cl	Chlorine Strip	12/06/21	0.1	<0.1	ppm	
Received Temp.		12/06/21	n/a	21.6	°C	

Comment(s) and Abbreviations:

CFUs: Colony Forming Units

ND: Not Detected

LOQ: Limit of Quantitation

68097

Chain of Custody - General

Client Enviroscience Consultants Inc.		Client Proj. ID 20251	Date 12/6/21		
Project Greenburgh CSD Legionella Water Testing 12/6/21		Address	Richard Bailey Elementary School		
Tech Chris Ortiz Turnaround			33 West Hillside Drive		
Time of Collection			White Plains, NY		
Sample ID.	Location and/or Sample Description	Material Sampled	Analysis	# and Type of Container	Preservative (if any)
1	Boiler Room-Hot Water Tank 10:32	Non Potable Water	Legionella	250 ml	Na2S2O3
2	3rd Floor- Bottle Filler @ Boys Room 10:36	Non Potable Water	Legionella	250 ml	Na2S2O3
3	3rd Floor Boys BR Sk Left 10:50	"	"	"	"



Relinquished: Christ Ortiz Signature: [Signature] Date: 12/6/21 Time: 12:06

Received: Cara Adams Signature: C. Adams Date: 12/6/21 Time: 12:06

Lab Use Only:

NYEA Project No.	Temp. <u>21.0</u> °C	Analyst Initials	Analysis Date:
------------------	----------------------	------------------	----------------